

Load Management located within DUQ Zone cannot be certified as Interruptible Load for Reliability (ILR) and is not eligible to receive RPM ILR credits in 2011/2012 DY since there was no ILR forecast for the DUQ zone withheld from the RPM demand curve for that DY and no ILR price was calculated. ILR is not applicable when the UCAP obligation for all load in a zone is satisfied using the FRR Alternative which is the case with the DUQ zone for the 11/12 DY.

Manual 18, Section 11, Fixed Resource Requirement Alternative lists the eligible supply resources in an FRR Capacity Plan. ILR is not listed as an eligible supply option for an FRR Capacity Plan.

<http://www.pjm.com/~media/documents/manuals/m18.ashx> **From Manual 18: 11.4.7 Load Management Products** A Load Management product (e.g., Direct Load Control, Firm Service Level, or Guaranteed Load Drop program) is eligible to be committed as a **Demand Resource (DR)** to the FRR Capacity Plan, if the product meets the requirements specified in the Load Data Systems Manual (M-19).